



Accessibility Report : Oceanside Village Resort, Parksville
Contact : Shauna Bookout – Front Desk Manager
Report Date : January 14, 2025
By : Ralph Tietjen

Property Overview

Oceanside Village Resort offers a collection of independent cottages of various sizes and configurations. All cottages have three steps up to the main entrance door, however on request the Resort can set up a ramp for wheelchair access. The main entrance doors are 33 inches in width and the interior doors are 27 inches in width. In the bathrooms only the toilet is accessible but the shower stall door opens towards the wheelchair preventing access. There are no handheld shower nozzles or grab bars installed.

There is one cottage (Unit 209) which may be considered as Accessible. It offers an open full length shower, but there is a big lip on the floor which does not allow roll-in access. There is a small grab bar on the far side and a seat set into the corner. There is a handheld shower nozzle and a raised toilet.

The office is accessible but there are no door actuators installed. The Pool building's entry door is not accessible, but once inside it is fully accessible. There are good stairs with railings down into the water for both the pool and hot tub.